



3

CONNECTION TO EXISTING SSMH

NTS

NOTES:

1. Inside or Outside Drops are prohibited;
2. Connection point must be water sealed by using a Kor-N-Seal boot.
3. Sewer by-pass must be in place prior to removing existing channel and making new connection;
4. Coordinate with the Midway Sewer District during any coring, connecting, and/or re-channeling.